



## **Thurrock Flexible Generation Plant**

---

### **Preliminary Environmental Information Report Appendix 11.4: Operational Noise Assessment Methodology and Results**

---

**Date:** September 2018

**Environmental Impact Assessment**

**Preliminary Environmental Information Report**

**Volume 6**

**Appendix 11.4**

---

Report Number: OXF10872

Version: Final

Date: September 2018

This report is also downloadable from the Thurrock Flexible Generation Plant website at:  
<http://www.thurrockpower.co.uk>

Thurrock Power Ltd

1st Floor

145 Kensington Church Street

London W8 7LP

**Copyright © RPS**

The material presented in this report is confidential. This report has been prepared for the exclusive use of Thurrock Power Ltd and shall not be distributed or made available to any other company or person without the knowledge and written consent of RPS.

Prepared by: Jon Baldwin

Contributors: Stephen Scott

Checked by: Simon Stephenson

## Table of Contents

|   |   |
|---|---|
| 1. Calculations and Modelling .....                   | 1 |
| 1.1 Noise source data & noise model methodology ..... | 1 |
| 1.1 Description of sound sources .....                | 1 |
| 1.2 Operating conditions .....                        | 1 |
| 1.3 Results .....                                     | 4 |
| 1.4 Assessment.....                                   | 4 |
| 1.5 Summary of Results.....                           | 7 |

It has been authorised by Simon Stephenson, a Technical Director within the Acoustics Team and full member of the Institute of Acoustics, who has 20 years' experience of environmental noise impact assessment.

## List of Tables

|   |   |
|---|---|
| Table 1.1: Operational breakdown of operational peaking plant facility. ....    | 2 |
| Table 1.2: Noise model inputs for individual noise generating plant items. .... | 3 |
| Table 1.3: Predicted specific sound levels at receptors. ....                   | 4 |
| Table 1.4: Partial sound pressure levels at receptors. ....                     | 4 |
| Table 1.5: BS 4142:2014 assessment of impact. ....                              | 5 |
| Table 1.6: Ambient noise level change assessment. ....                          | 6 |

## List of Figures

|   |   |
|---|---|
| Figure 1.1: Average operational hours per day over a year. .... | 2 |
|---|---|

## Summary

This Appendix provides supporting information on the assessment methodology and modelling results regarding operational noise impacts associated with Thurrock FGP. Discussion of the results presented within this Appendix, is presented in Chapter 11: Noise and Vibration.

## Qualifications

This document has been prepared by Jon Baldwin, a Senior Acoustic Consultant and full Member of the Institute of Acoustics, who has six years' experience of environmental noise impact assessment.

It has been checked by Stephen Scott, a Senior Acoustic Consultant and full member of the Institute of Acoustics, who has 20 years' experience of environmental noise impact assessment.

# 1. Calculations and Modelling

## 1.1 Noise source data & noise model methodology

- 1.1.1 Noise source data for the assessment has been based on manufacturer’s data provided to the project team by the equipment manufacturer. Where other manufacturers’ data are not available, measurement data obtained by RPS during operational compliance surveys on similar gas-fired engine reserve facilities has been used to determine appropriate sound power levels for the chosen equipment.
- 1.1.2 Source levels have been supplied by the manufacturer on the broadband sound power level of the transformers.
- 1.1.3 In order to determine the specific sound levels resulting from the operation of the proposed development, a noise model has been built using SoundPlan v8 noise modelling software. The model predicts noise levels under light down-wind conditions based on hemispherical propagation, atmospheric absorption, ground effects, screening and directivity based on the procedure detailed in ISO 9613-2:1996 (International Organisation for Standardisation (ISO), 1996).

## 1.1 Description of sound sources

- 1.1.1 The maximum design envelope parameters are detailed in Volume 3, Chapter 11: Noise and Vibration.
- 1.1.2 Each gas engine has been modelled housed within individual enclosures (27.8 (L) x 6.5 (W) x 7.5 (H) m). Each engine enclosure has an associated stack/exhaust terminating at 40 m above ground level (AGL), air inlet louvres at the ends of the enclosures and air outlet louvres on the roof. Connection from the main gas network to the facility is provided via a gas kiosk enclosure. The inverters, batteries and air cooling plant are containerised.
- 1.1.3 The radiators for the gas engines are positioned 5.5 m AGL. Air coolers associated with the containerised battery and inverter units are located approximately 1.7 m AGL. The measurement data used for the assessment are representative of radiators and coolers operating at 100% cooling capacity. As such, the predicted sound levels due to the radiators and coolers are a worst case and representative of the proposed development operating at full capacity with ambient air temperatures in excess of 30 °C. These conditions are most unlikely to regularly occur at any time, particularly during the evening and even less so during the night-time. Consequently, the assessment is likely to be over precautionary for the evening and night-time periods.

- 1.1.4 Based on professional experience and review of available data, all sound sources associated with the engines, including the air inlets, outlets and radiators, are considered to produce sound with broadband frequency content. The containerised battery units produce broadband sound with tonal components, however it is the AC units and inverters which are dominant and as such, it is considered that the overall emissions from the containers are broadband in character. The transformers produce broadband sound with a tonal component at 100 Hz and harmonics thereof at source.
- 1.1.5 Details on the sound power levels for various plant items used within the noise model is presented in Table 1.2.

## 1.2 Operating conditions

- 1.2.1 The proposed development is planned to operate during peak periods of electricity demand or to prevent system instability (i.e. typically for a period ranging from one to seven hours, between 08:00 and 20:00 hrs). However, there is the potential that the proposed development could be required to operate during a major power shortage or system stress events (e.g. a Notification of Inadequate System Margin (NISM)) at any time of the day or night. It should be noted that the likelihood of the facility being required to start up at night is extremely low as peak demand does not occur overnight.
- 1.2.2 Figure 1.1 below indicates the anticipated average hours of operation per day in each month.




Figure 1.1: Average operational hours per day over a year.

1.2.3 A yearly breakdown of operating time for similar operational peaking plant is presented in Table 1.1.

Table 1.1: Operational breakdown of operational peaking plant facility.

| Season | Period (hours) | Percentage total operational time | Approx. operational hours (assuming 1,500 hr yearly total) |
|--------|----------------|-----------------------------------|--|
| Winter | 0400 – 0700    | 1                                 | 15   |
|        | 0700 – 1600    | 19                                | 285  |
|        | 1600 – 1900    | 27                                | 405  |
|        | 1900 – 2300    | 6                                 | 90   |
| Summer | 0400 – 0700    | 1                                 | 15   |
|        | 0700 – 1600    | 22                                | 330  |
|        | 1600 – 1900    | 17                                | 255  |
|        | 1900 – 2300    | 6                                 | 90   |
| All    | 2300 - 0400    | 0.2                               | 2  |

1.2.4 As can be seen from Table 1.1, operational hours during night-time periods totalled two hours over the course of a year, assuming a 1,500 hr yearly total operating time, at an operational peaking plant facility. Whilst the maximum design envelope parameters for the proposed development have considered an operational yearly total of 4,000 hours, it is considered that the majority of additional operating hours would be during the day and evening periods and, as such, any increase in night-time operation would be minimal.

Table 1.2: Noise model inputs for individual noise generating plant items.

| Source                                 | Number | Height above ground<br>m | Overall sound power level<br>dBA | Linear octave band sound power levels<br>dB |       |        |        |        |       |       |       |       |
|--|--------|--------------------------|----------------------------------|---|-------|--------|--------|--------|-------|-------|-------|-------|
|  |        |                          |                                  | 31.5 Hz                                     | 63 Hz | 125 Hz | 250 Hz | 500 Hz | 1 kHz | 2 kHz | 4 kHz | 8 kHz |
| Engine enclosure                       | 60     | 7.5                      | 90                               | -   | 80    | 65     | 57     | 45     | 37    | 26    | 15    | 16    |
| Exhaust body and ductwork              | 60     | 4.5 – 1.75               | 85                               | -   | 95    | 86     | 88     | 79     | 76    | 72    | 78    | 72    |
| Exhaust outlet                         | 60     | 40                       | 80                               | 117   | 101   | 80     | 70     | 40     | 41    | 44    | 36    | 25    |
| Radiators                              | 120    | 5.5                      | 75                               | -   | 94    | 85     | 75     | 73     | 65    | 59    | 45    | 50    |
| Air inlet                              | 240    | 3                        | 77                               | -   | 86    | 84     | 79     | 71     | 63    | 62    | 72    | 65    |
| Air outlet                             | 120    | 10                       | 80                               | -   | 91    | 84     | 78     | 79     | 66    | 71    | 74    | 69    |
| Gas kiosk building                     | 1      | 5                        | 63                               | -   | 74    | 56     | 57     | 60     | 57    | 58    | 43    | 30    |
| Battery containers (walls/roof)        | 52     | 6                        | 72                               | 78  | 78    | 74     | 71     | 69     | 67    | 64    | 59    | 60    |
| Battery container inverter air intakes | 104    | 2.75 – 5.75              | 72                               | -   | 63    | 66     | 67     | 68     | 66    | 66    | 62    | 58    |
| Battery container AC units             | 208    | 1.5                      | 76                               | 85  | 82    | 80     | 75     | 73     | 72    | 66    | 63    | 58    |
| Transformer                            | 8      | 2                        | 83                               | -   | 79    | 84     | 83     | 83     | 77    | 72    | 67    | 60    |
| Transformer (132 kV – 275 kV)          | 3      | 2                        | 91                               | -   | 87    | 92     | 91     | 91     | 85    | 80    | 75    | 68    |

## 1.3 Results

1.3.1 The predicted specific sound levels at the identified worst affected noise sensitive receptors (NSRs), as described in Volume 3, Chapter 11: Noise and Vibration, due to the operation of Thurrock Flexible Generation Plant are provided in Table 1.3.

**Table 1.3: Predicted specific sound levels at receptors.**

| Receptor         | Floor        | Predicted Specific Sound level<br>L <sub>s</sub> dB(A) |
|------------------|--------------|--|
| Byron Gardens    | Ground Floor | 36   |
|                  | First Floor  | 37   |
| Gun Hill Farm    | Ground Floor | 35   |
|                  | First Floor  | 35   |
| Galsworthy Road  | Ground Floor | 35   |
|                  | First Floor  | 36   |
| Havers Lodge     | Ground Floor | 38   |
|                  | First Floor  | 39   |
| Buckland         | Ground Floor | 33   |
|                  | First Floor  | 35   |
| St James' Church | Ground Floor | 36   |
|                  | First Floor  | 37   |

1.3.2 The model results indicating the partial sound pressure level contribution from each individual source of noise from the proposed development to the receptors listed above is presented in Table 1.4.

**Table 1.4: Partial sound pressure levels at receptors.**

| Source             | Byron Gardens | Gun Hill Farm | Galsworthy Road | Havers Lodge | Buckland | St James' Church |
|--------------------|---------------|---------------|-----------------|--------------|----------|------------------|
| <b>Gas Engines</b> |               |               |                 |              |          |                  |
| Air Inlets         | 26            | 24            | 25              | 19           | 24       | 24               |
| Air Outlets        | 26            | 25            | 25              | 28           | 26       | 28               |
| Engine enclosures  | 30            | 29            | 29              | 32           | 28       | 30               |

| Source  | Byron Gardens | Gun Hill Farm | Galsworthy Road | Havers Lodge | Buckland | St James' Church |
|---|---------------|---------------|-----------------|--------------|----------|------------------|
| Exhaust ducts                                 | 23            | 21            | 22              | 28           | 22       | 24               |
| Exhaust outlets                               | 29            | 28            | 27              | 31           | 27       | 29               |
| Gas kiosk building                            | -5            | -5            | -6              | 1            | -4       | -2               |
| Radiators                                     | 22            | 21            | 21              | 26           | 21       | 24               |
| Stack body                                    | 29            | 28            | 28              | 31           | 28       | 29               |
| <b>Battery containers</b>                     |               |               |                 |              |          |                  |
| AC units                                      | 29            | 24            | 27              | 26           | 18       | 26               |
| Air inverter intake                           | 21            | 17            | 20              | 19           | 10       | 18               |
| Battery containers                            | 19            | 15            | 18              | 17           | 9        | 16               |
| <b>Substation</b>                             |               |               |                 |              |          |                  |
| Transformers 33 kV – 132 kV & 11 kV to 132 kV | 20            | 16            | 18              | 17           | 15       | 16               |
| Transformers 132 kV to 275 kV                 | 24            | 19            | 23              | 20           | 18       | 20               |

1.3.3 The predicted source contribution levels given in Table 1.4, indicate that the transformer, provides a negligible contribution to the overall noise level from the proposed development. As it is considered that the only source of tonal noise from the proposed development is from the transformer, it is most unlikely that noise levels at the nearby NSRs would be perceived or characterised as tonal.

1.3.4 Operational noise contours are provided in Figure 4.18 and Figure 4.19, Volume 3, Chapter 11: Noise and Vibration.

## 1.4 Assessment

### BS 4142:2014 assessment

1.4.1 An initial estimate of impact undertaken in accordance with BS 4142:2014 'Methods for rating and assessing industrial and commercial sound' (British Standards Institution (BSI), 2014), is shown in Table 1.5 for the daytime, evening and night-time periods. Predicted specific sound levels for the day and evening are taken at ground floor level with night time level taken at first floor level.

1.4.2 The subjective method for determining rating penalties has been used to determine appropriate corrections for each receptor and assessment period. It is considered that the specific sound will not be characterised as intermittent or impulsive, therefore no penalties have been applied for intermittency or impulsivity. As it is considered that the only source of tonal noise from the proposed development is from the transformer and the contribution from this source to the overall specific sound is negligible, it is most unlikely that noise levels at the nearby NSRs would be perceived or characterised as tonal. As such, no penalties have been applied for tonality.

Table 1.5: BS 4142:2014 assessment of impact.

| Location         | Representative baseline sound levels |                                   | Specific sound level<br>dB L <sub>s</sub> | Rating penalty<br>dB | Rating level<br>dB L <sub>Ar,Tr</sub> | Rating level difference<br>dB |
|------------------|--------------------------------------|-----------------------------------|---|----------------------|---------------------------------------|-------------------------------|
|                  | Background<br>dB L <sub>A90,T</sub>  | Residual dB<br>L <sub>Aeq,T</sub> |   |                      |                                       |                               |
| <b>Day</b>       |                                      |                                   |   |                      |                                       |                               |
| Byron Gardens    | 40                                   | 61                                | 36  | 0                    | 36                                    | -4                            |
| Gun Hill Farm    | 39                                   | 48                                | 35  | 0                    | 35                                    | -4                            |
| Galsworthy Road  | 40                                   | 61                                | 35  | 0                    | 35                                    | -5                            |
| Havers Lodge     | 42                                   | 57                                | 38  | 0                    | 38                                    | -4                            |
| Buckland         | 38                                   | 48                                | 33  | 0                    | 33                                    | -5                            |
| St James' Church | 39                                   | 48                                | 36  | 0                    | 36                                    | -3                            |
| <b>Evening</b>   |                                      |                                   |   |                      |                                       |                               |
| Byron Gardens    | 36                                   | 55                                | 36  | 0                    | 36                                    | 0                             |
| Gun Hill Farm    | 33                                   | 44                                | 35  | 0                    | 35                                    | +2                            |
| Galsworthy Road  | 36                                   | 55                                | 35  | 0                    | 35                                    | -1                            |
| Havers Lodge     | 36                                   | 49                                | 38  | 0                    | 38                                    | +2                            |
| Buckland         | 34                                   | 42                                | 33  | 0                    | 33                                    | -1                            |
| St James' Church | 33                                   | 44                                | 36  | 0                    | 36                                    | +3                            |

| Location         | Representative baseline sound levels |    | Specific sound level | Rating penalty | Rating level<br>dB L <sub>Ar,Tr</sub> | Rating level difference |
|------------------|--------------------------------------|----|----------------------|----------------|---------------------------------------|-------------------------|
| <b>Night</b>     |                                      |    |                      |                |                                       |                         |
| Byron Gardens    | 35                                   | 49 | 37                   | 0              | 37                                    | +2                      |
| Gun Hill Farm    | 34                                   | 41 | 35                   | 0              | 35                                    | +1                      |
| Galsworthy Road  | 35                                   | 49 | 36                   | 0              | 36                                    | +1                      |
| Havers Lodge     | 33                                   | 45 | 39                   | 0              | 39                                    | +6                      |
| Buckland         | 32                                   | 39 | 35                   | 0              | 35                                    | +3                      |
| St James' Church | 34                                   | 41 | 37                   | 0              | 37                                    | +3                      |

1.4.3 The results of the initial estimate of impact in Table 1.5 are described in the following paragraphs.

1.4.4 During the daytime, when the proposed development is most likely to operate, the rating level is 3 dB below the background sound level at the most affected receptor, St James' Church. This is 8 dB below the threshold level at which a moderate impact is likely. At the other receptors, predicted rating levels are between 4 dB and 5 dB below background sound levels. The results of the initial estimate of impact during the daytime are therefore indicative of negligible impacts at all receptors, depending on the context.

1.4.5 During the evening, the rating level is 3 dB above the background sound level at the most affected receptor, St James' Church. This is 2 dB below the threshold level at which a moderate impact is likely. At the other receptors, predicted rating levels are between 2 dB above and 1 dB below background sound levels. This is indicative of negligible or minor impacts at all receptors, depending on the context.

1.4.6 During the night-time, when the proposed development is least likely to operate, the rating level is 6 dB above the background sound level at the most affected receptor, Havers Lodge. This is indicative of a moderate impact at this receptor, depending on the context. At the other receptors, predicted rating levels are between 1 dB and 3 dB above background sound levels. This is indicative of minor impacts at all other receptors, depending on the context.



1.4.7 To accord with the guidance contained within BS 4142:2014 and provide a thorough assessment, consideration of the context of the scenario has been undertaken. Consideration of the context is provided in terms of the assessment of the absolute noise levels and the change in ambient sound due to the specific sound as addressed further on in this section.

### Likely operating conditions and national demand

1.4.8 Data which are currently available on the likely operating regime of the proposed development indicates that it will only ever run during the night-time in exceptional circumstances when there is insufficient generation from alternative sources and there are significant unplanned outages in baseload generation. As can be seen from Table 1.1, night-time operating hours of similar peaking plant developments are minimal.

1.4.9 The average operational hours per day provided in Figure 1.1 indicate that, during the more sensitive warmer months (April to September) when people are more likely to have windows open or to be outside, the proposed development will operate for fewer hours on any given day. The cooler months (from October to March) are less sensitive because people are more likely to have windows closed or to be inside.

1.4.10 Local and national demand for energy infrastructure of this type is being driven by changes in how energy is generated, stored and distributed. Large, centralised, fossil fuel based energy generation is in decline and the decline is projected to continue. Recent projections undertaken by the applicant, indicate substantial increases in the proportion of energy which will be delivered by renewable energy sources in the near future; however, renewable energy generation can be intermittent. As such, the demand for developments of this type which are able to step-in and provide support to the network in periods of high demand has increased. The proposed development will be providing critical support to meet local demand and to balance the national grid.

### Noise change and absolute noise level assessment

1.4.11 The ambient sound levels, with and without the proposed development in operation, are shown in Table 1.6. For steady sources of a similar character, a 3 dB change is generally taken as the minimum change which is perceptible to most people.

Table 1.6: Ambient noise level change assessment.

| Location         | Baseline residual sound level<br>dB L <sub>Aeq,T</sub> | Specific sound level<br>dB L <sub>Aeq,T</sub> | Combined sound level<br>dB L <sub>Aeq,T</sub> | Change in sound level<br>dB |
|------------------|--|---|---|-----------------------------|
| <b>Day</b>       |  |   |   |                             |
| Byron Gardens    | 61   | 36  | 61  | 0                           |
| Gun Hill Farm    | 48   | 35  | 48  | 0                           |
| Galsworthy Road  | 61   | 35  | 61  | 0                           |
| Havers Lodge     | 57   | 38  | 57  | 0                           |
| Buckland         | 48   | 33  | 48  | 0                           |
| St James' Church | 48   | 36  | 48  | 0                           |
| <b>Evening</b>   |  |   |   |                             |
| Byron Gardens    | 55   | 36  | 55  | 0                           |
| Gun Hill Farm    | 44   | 35  | 45  | +1                          |
| Galsworthy Road  | 55   | 35  | 55  | 0                           |
| Havers Lodge     | 49   | 38  | 49  | 0                           |
| Buckland         | 42   | 33  | 43  | +1                          |
| St James' Church | 44   | 36  | 45  | +1                          |
| <b>Night</b>     |  |   |   |                             |
| Byron Gardens    | 49   | 37  | 49  | 0                           |
| Gun Hill Farm    | 41   | 35  | 42  | +1                          |
| Galsworthy Road  | 49   | 36  | 49  | 0                           |
| Havers Lodge     | 45   | 39  | 46  | +1                          |
| Buckland         | 39   | 35  | 40  | +1                          |
| St James' Church | 41   | 37  | 42  | +1                          |

- 1.4.12 Increases of 1 dB above baseline residual sound levels are predicted during the evening and night-time periods at Gun Hill Farm, Buckland and St James' Church, as a result of the operation of the proposed development. An increase of 1 dB above baseline residual sound levels is predicted at Havers Lodge during the night-time only. For a steady sound source with no discernible impulsive or tonal characteristics, a 3 dB change is generally taken as the minimum change which is perceptible to most people. As such, an increase above baseline residual sound levels of 1 dB, as presented in Table 1.6, is unlikely to be noticeable.
- 1.4.13 It has been demonstrated above that the specific sound level is significantly below the existing ambient noise level during the day and will not contribute to or cause any change to ambient noise levels. It is therefore considered that sound from the proposed development is most unlikely to cause, or significantly contribute to, any exceedance of the World Health Organisation (WHO) criterion for the onset of annoyance during the daytime, of 55 dB  $L_{Aeq}$ . It is therefore considered that the site will not result in adverse effects to amenity during the daytime.
- 1.4.14 The level for the onset of sleep disturbance during the night-time (i.e. lowest observed adverse effect level) contained in the WHO Guidance is 45 dB  $L_{Aeq}$  (façade), equivalent to a free-field level of 42 dB  $L_{Aeq}$ . Whilst this threshold level is exceeded at a number of receptors, the contribution from the proposed development to the overall sound level is negligible. It is therefore considered that, whilst WHO guideline levels may be exceeded, the impact from the operation of the proposed development during the night on sleep disturbance will be minimal.

## 1.5 Summary of Results

- 1.5.1 The determination of magnitude of impact at the identified receptors from the operation of the proposed development and corresponding significance is detailed Volume 3, Chapter 11: Noise and Vibration.

## 2. References

British Standards Institution (BSI) (2014) British Standard 4142:2014. Methods for rating and assessing industrial and commercial sound.

International Organisation for Standardisation (ISO) (1996) ISO 9613-2:1996. Acoustics: Attenuation of sound during propagation outdoors – Part 2: General method of calculation.